Pressure Switch with Analog Output (IO-Link) 611537 (46926-40)



LabVolt Series

Datasheet



Table of Contents

| General Description | . 3 |
|------------------------------------|-----|
| List of Manuals | 3 |
| Table of Contents of the Manual(s) | 3 |

© Festo Didactic 2

General Description

The Pressure Switch with Analog Output is a digital pressure gauge ranging from 0 kPa (0 psi) to 1000 kPa (145 psi). It features a 4-20 mA output signal proportional to a user-defined upper value. A relay can be configured so as to become activated when the measured pressure rises above a threshold value.

The pressure switch can be configured using the TP 1312 Smart Sensors.

List of Manuals

| Description | Manual number |
|---|-------------------|
| Pressure and Level Switches (Workbook) | 585143 (86000-00) |
| Pressure and Level Switches (Workbook (Instructor)) | 585144 (86000-10) |

Table of Contents of the Manual(s)

Pressure and Level Switches (Workbook) (585143 (86000-00))

- 1 Pressure Switch
- 2 Float Switch
- 3 Vibrating Level Switch
- 4 Conductivity Level Switch

3 © Festo Didactic

Reflecting the commitment of Festo Didactic to high quality standards in product, design, development, production, installation, and service, our manufacturing and distribution facility has received the ISO 9001 certification.

Festo Didactic reserves the right to make product improvements at any time and without notice and is not responsible for typographical errors. Festo Didactic recognizes all product names used herein as trademarks or registered trademarks of their respective holders. © Festo Didactic Inc. 2025. All rights reserved.

Festo Didactic SE

Rechbergstrasse 3 73770 Denkendorf Germany

P. +49(0)711/3467-0 F. +49(0)711/347-54-88500

Festo Didactic Inc.

607 Industrial Way West Eatontown, NJ 07724 United States

P. +1-732-938-2000 F. +1-732-774-8573

Festo Didactic Ltée/Ltd

675 rue du Carbone Québec QC G2N 2K7 Canada

P. +1-418-849-1000 F. +1-418-849-1666

www.labvolt.com

www.festo-didactic.com

© Festo Didactic 4